


PRODUCT COMPLIANCE SCHEDULE

Foshan Wansley Industrial Co., Ltd.

COMPANY ADDRESS: No. 11, Luocun Avenue North, Lutang Community, Shishan Town, Nanhai District, Foshan, Guangdong, China, 528226

This schedule identifies the Certified Product(s) on which the PAS-Mark and CSi Licence Number may be used.

AS 2047:2014 Windows and external glazed doors in buildings

SCOPE OF CERTIFICATION							
Fenestration Type	Model ID	Model Description	SLS Design Wind Pressure (Pa)	ULS Design Wind Pressure (Pa)	Water Penetration Resistance (Pa)	Air Infiltration Rating	Date of Endorsement
	130 Series.	130 Series Casement-Sliding Combination Door	1600 Pa Rating: N6/C4 (General)	5300 Pa Rating: N6/C4 (General)	No water penetration at: 0 Pa for 5 mins and 600Pa for 15 mins. Rating: N6/C4 (Exposed)	At +75Pa 0.97 L/s m² At -75Pa 0.90 L/s m² Rating: Low	22 October 2025 Test Report No. EET-2025QCFS1-0186(E)
			PASS	PASS	PASS	PASS	
Dimension of Window Frame:		1800 mm(Width)×2200 mm(Height)×130 mm(Thickness)					
Dimension of Window Sash:		Operable Sash: 796 mm(Width) × 2028 mm(Height) × 38 mm(Thickness)					
Frame Corner Construction Details:		Mechanically assembled by Corner Combining Machine, then Glued and sealed.					
Hardware:		Hinge, Model:CML003, D-Lock Model: T-LSGS01, Supplier: Guangdong Kinlong Hardware Products Co., LTD.					
Drainage:		Sizes: 25 mm (Width) × 5 mm (Height) Quantity: 4					
Gasket (between the sash and the frame)		Model: F1129; Material: EPDM; Supplier: Oudingrui Rubber Technology (Guangdong) Co., Ltd.					
Thermal break:		Model: I10, Code: HH-002, Model: I12, Code: HH-003, Material: PA66GF25, Supplier: Foshan Ligao New Materials Technology Co., Ltd.					
Reinforcement:		None.					
1. This certification excludes, Section 7 installation. 2. Energy rating: Results not provided.							

This schedule supersedes any previously issued schedule.

CSi Licence Number:
Certification Issue Date:
Certification Expiry Date:
CSi Schedule Number:

8810
25 October 2026
24 October 2027
CSi Lic 8810-2026-10-S1-R0

Certification Review Date: 05 August 2026
Next Annual Review Date: 25 Sep. 2027
CSi Database ID Number: 1880452


Azma Khan
Managing Director



<https://register.jasanz.org>



<https://iaf.nu/en/mla-mark/>



The current validity of this document should be checked by contacting admin@csi-certification.com PASF_015 I1R3
This document is the property of CSi and must be returned to CSi upon its request. This document may only be reproduced in its entirety.